



GSP SCHILLER

400 Gosling Road  
Portsmouth, NH 03801

December 14, 2020

Submitted on-line via NetDMR

U.S. Environmental Protection Agency  
Region 1  
Water Compliance Section (Mail Code 04-SMR)  
5 Post Office Square - Suite 100  
Boston, MA 02109-3912

Reference: NPDES Permit No. NH0001473, Schiller Station, GSP Schiller LLC,  
effective July 1, 2018.

Dear Sir/Madam:

Schiller Station  
Monthly NPDES Discharge Monitoring Report  
November 2020

In compliance with Part I, Section B.1., of the NPDES permit (see Reference), Granite Shore Power LLC (GSP) submits the monthly report for Schiller Station for October. With the following exception, all sampling and analyses were conducted by station personnel in accordance with EPA approved procedures referenced at 40 CFR Part 136; ChemServe Environmental Analysts of Milford, NH, performed the total suspended solids and oil and grease analyses required for the reporting period. As instructed by the agencies, GSP reports a concentration of zero ("0") when the analytical result is less than the method detection limit (MDL). For this report, the following MDL was used: Oil & Grease = 5.0 mg/l (EPA 1664A). There were no permit noncompliances recorded during the month.

This report is required by, and prepared specifically for, the U.S. Environmental Protection Agency (EPA). It presents truly, accurately and completely, the observed measurements and analyses required by the EPA to be performed or submitted, but only such observed results. It is not intended as an assertion of the accuracy of any instrument, reading, or analytical result, nor is it an endorsement of the suitability of any analytical or measurement procedure.

EPA Water Compliance Section


Page 2

December 14, 2020

If you have any questions regarding this report, please contact Allan Palmer, Senior Engineer, at (603) 230-7951.

Sincerely,

GRANITE SHORE POWER



---

Elizabeth H. Tillotson

Executive Director of Administration & Regulatory Affairs

Enclosures